



Garden State Laboratories, Inc.

Report of Analysis

410 Hillside Ave.
Hillside, NJ 07205

Telephone: 800-273-8901
Email: info@gslabs.com
Internet: www.gslabs.com

Main Lab
NJDEP Lab Cert. #20044

Jersey Shore Lab
NJDEP Lab Cert. #15037

Lakehurst Lab
NJDEP Lab Cert. #15041

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A. Laboratory Manager

For: David Gregory School
347 North Farview Ave.

Paramus, NJ 07652

Laboratory Director:

Report Date: 08/14/2024

Attention: David Ruzick

Client Number: DAV41

Sample ID: David Gregory School - 347
North Fairview Ave, Paramus,
NJ 07652/Field Blank

Lab Sample ID: 240807022-01

Site: Collection Date/Time: 08/06/2024 07:58

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	08/13/24 11:58	

Sample ID: David Gregory School - 347
North Fairview Ave, Paramus,
NJ 07652/Kitchen Sink Window
#1

Lab Sample ID: 240807022-02

Site: Collection Date/Time: 08/06/2024 07:59

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00136 mg/l	0.015	0.00100	0.00055	20044	08/13/24 12:01	

Sample ID: David Gregory School - 347
North Fairview Ave, Paramus,
NJ 07652/Kitchen Sink - A/C #2

Lab Sample ID: 240807022-03

Site: Collection Date/Time: 08/06/2024 07:59

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00152 mg/l	0.015	0.00100	0.00055	20044	08/13/24 12:10	

DF=Dilution factor, <=less than, MCL=Maximum Contaminant Level, Rep. Limit=Reporting Limit,
MDL=Method Detection Limit, SM YR=Standard Methods Publication Year, and NC=Not Certified.
The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.